


Notes:

1. Concrete Strength 32 MPa @ 28 Days
2. Concrete contains MacMatrix 2" Fibers
3. Lid Sealed with Conseal CS-665
4. 2 - 20" Polylok Risers
5. Polylok A1800 Effluent Filter
6. Tank Weight: 4700 LBS
7. Lid Weight: 1600 LBS



**DAN'S**  
*Pre-Cast*  
**LTD.**

6100 Scott Rd.  
Duncan, B.C.  
250-746-7400  
[www.dansprecast.com](http://www.dansprecast.com)

**600 IMP. GAL. 2 COMP.  
(2722 LITRES)**

Gals/inch Big Chamber: 12.33 Small Chamber: 4.57

DATE: NOVEMBER 26, 2018

DRAWN BY:

EJG