



Notes:

1. Concrete Strength 32 MPa @ 28 days
2. Concrete contains MacMatrix 2" Fibers
3. Lid Sealed with Conseal CS-665
4. 2 - 20" Polylok Risers
5. Polylok A1800 4" x 18" Effluent Filter
6. Tank Weight: 5300 LBS
7. Lid Weight: 1600 LBS

DAN'S
Pre-Cast
LTD.

6100 Scott Rd.
Duncan, B.C.
250-746-7400
www.dansprecast.com

**750 IMP. GAL. 2 COMP.
(3409 LITRES)**

Gals/inch 1st Chamber: 13.71 2nd Chamber: 3.53

DATE: NOVEMBER 26, 2018

DRAWN BY:

EJG